



**BUREAU  
VERITAS**

# Certificate of compliance

**Applicant:** SolaX Power Network Technology (Zhe jang) Co., Ltd.  
No. 288 Shizhu Road, Tonglu Economic Development Zone,  
Dongxing District 311500, Tonglu City, Zhejiang Province  
China

**Product:** Hybrid inverter

**Model:** X3-Hybrid-5.0-D-C, X3-Hybrid-5.0-N-C, X3-Hybrid-5.0-D-E, X3-Hybrid-5.0-N-E, X3-Hybrid-6.0-D-C, X3-Hybrid-6.0-N-C, X3-Hybrid-6.0-D-E, X3-Hybrid-6.0-N-E, X3-Hybrid-8.0-D-C, X3-Hybrid-8.0-N-C, X3-Hybrid-8.0-D-E, X3-Hybrid-8.0-N-E, X3-Hybrid-10.0-D-C, X3-Hybrid-10.0-N-C, X3-Hybrid-10.0-D-E, X3-Hybrid-10.0-N-E, X3-Fit-8.0C, X3-Fit-8.0E, X3-Fit-10.0C, X3-Fit-10.0E

## Use in accordance with regulations:

Automatic disconnection device with three-phase mains surveillance in accordance with NRS 097-2-1:2017 for photovoltaic systems with a three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverters.

## Applied rules and standards:

### NRS 097-2-1:2017 Edition 2

Grid interconnection of embedded generation, Part 2: Small-scale embedded generation, Section 1: Utility interface

Comply with:

Category A1: 0 – 13,8 kVA

Category A2: 13,8 kVA – 100 kVA

### IEC 61727:2004 Edition 2

Photovoltaic (PV) systems – Characteristics of the utility interface

### IEC 62116:2008 Edition 1 / IEC 62116:2014 Edition 2

Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters

### VDE AR-N 4105:2011-08 (A.6 General requirements, single-fault tolerance)

Power generation systems connected to the low-voltage distribution network

Note:

The inverter(s) are comply with IEC/EN 61000-6-2 "Electromagnetic compatibility (EMC) – Part 6-2: Generic standards – Immunity standard for industrial environments, IEC/EN 61000-6-3 Electromagnetic compatibility (EMC) – Part 6-3: Generic standards – Emission standard for residential, commercial and light-industrial" and EN 50065-1:2011 "Signalling on low-voltage electrical installations in the frequency range 3kHz to 148,5kHz".

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

**Report number:** SXP-18SE2165FCSHP

**Certificate number:** U18-0570

**Date of issue:** 2018-10-18

**Certification body**



Holger Schaffer

Certification body of Bureau Veritas Consumer Products Services Germany GmbH  
Accredited according to DIN EN ISO/IEC 17065